



SCAFFOLD

Site Address: _____

Hazard		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
1	Was the scaffold erected under the supervision and direction of a qualified person?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
2	If the scaffold is over 36', was a permit obtained?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
3	Have the scaffold erectors been properly trained?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
4	Are scaffolding components and planking safe condition for use?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
5	Have hazardous environmental conditions been accounted for, i.e. power lines, wind, possible washout of footings?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
6	Is only scaffold grade planking being used?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
7	Is the scaffolding capable of carrying the intended load?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
8	Have screw jacks been used to level and plumb the scaffold instead of unstable objects such as concrete blocks, loose bricks, wood, etc.?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
9	Are scaffolding platforms level (the slope should be no more than 2:10)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
10	Are base plates being used on all scaffold legs and, if so, are they installed correctly?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
11	Are the scaffold legs resting on base plates provided by the manufacturer?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
12	Are the based plates resting on and nailed to 2X10X10 wood bases when on earth or soft material?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
13	Is scaffolding completely railed?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
14	Top rails at 42"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
15	Mid rail or cross bar	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
16	End rails	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
17	Has proper access been provided to all levels of the scaffolding?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
18	If ladders are used to access the scaffold, are the ladders in good condition, properly braced, properly anchored, and extend 36" above the platform?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
19	Are braces installed to reinforce the legs of the scaffold.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
20	Have toeboards been installed where they are necessary and are they installed properly?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
21	If the height of the scaffold exceeds 3 times the least base dimension of the frame, are ties, stabilizers, or outriggers used?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
22	If ties are used, is the scaffold tied off using 10 gauge (single looped) or 12 gauge (double looped) wire?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
23	Are the tie offs tied to the structure at each end of the scaffold and then every 30' horizontally and 26' vertically?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
24	Have free standing towers been guyed or tied every 26' in height?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
25	Is the scaffold anchored to prevent tipping into or away from the structure?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
26	Is scaffold fully planked between the uprights where employees are working?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		



SCAFFOLD

27	Does the planking have a minimum 12" overlap and extend at least 6", but not more than 18", beyond the supports?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
28	Are the the inboard plank edges no more than 16 inches from the structure?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
29	Are there no planks placed on top or midrails?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
30	Where the scaffold is used for edge protection, is a 2"x6" toeboard attached to the outer uprights?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
31	Where scaffolding is used as edge protection, does the rail extend 42" above the eaves (if the outboard edge of the platform is closer than 12" to the eave)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Qualified person for scaffold erection is: _____

Inspected by: _____ Date: _____

Actions Taken to Correct Items Checked as "Needs Attention"

Hazard #	
Hazard #	
Hazard #	
Hazard #	
Hazard #	

Links to Additional Resources

State Fund Resources:

State Fund Tailgate Topics on Scaffolds.
<https://www.safeatworkca.com/safety-articles/scaffolding-requirements/>

State Fund Scaffold Videos
<https://www.youtube.com/watch?app=desktop&v=R-elGPRABFw>
<https://www.youtube.com/watch?app=desktop&v=5pmLt7lhcpI>

Cal/OSHA Resources:

Cal/OSHA's Guide for Working Safely with Supported Scaffolds
https://www.dir.ca.gov/dosh/dosh_publications/GuideForSupportedScaffolds.pdf

Cal/OSHA Regulations
<https://www.dir.ca.gov/Title8/1637.html>
<https://www.dir.ca.gov/Title8/1644.html>
<https://www.dir.ca.gov/Title8/1646.html>