

Fire safety maintenance checklist

	Yes	No	N/A	Comments	
Daily checks (not normally recorded)					
Escape routes					
Can all fire exits be opened immediately and easily?					
Are fire doors clear of obstructions?					
Are escape routes clear?					
Fire warning systems					
Is the indicator panel showing 'normal'?					
Are whistles, gongs or air horns in place?					
Escape lighting					
Are luminaires and exit signs in good condition and undamaged?					
Is emergency lighting and sign lighting working correctly?					
Firefighting equipment					
Are all fire extinguishers in place?					
Are fire extinguishers clearly visible?					
Are vehicles blocking fire hydrants or access to them?					
Weekly checks					
Escape r outes					
Do all emergency fastening devices to fir e exits (push bars and pads, etc.) work correctly?					
Are external routes clear and safe?					
Fire warning systems					
Does testing a manual call point send a signal to the indicator panel? (Disconnect the link to the r eceiving centre or tell them you are doing a test.)					
Did the alarm system work correctly when tested?					
Did staff and other people hear the fir e alarm?					
Did any linked fire protection systems operate correctly? (e.g. magnetic door holder r eleased, smoke curtains drop)					
Do all visual alarms and/or vibrating alarms and pagers (as applicable) work?					
Do voice alarm systems work correctly? Was the message understood?					
Escape lighting					
Are charging indicators (if fitted) visible?					
Firefighting equipment					
Is all equipment in good condition?					
Additional items from manufacturer's recommendations.					

	Yes	No	N/A	Comments
Monthly checks				
Escape routes				
Do all electronic release mechanisms on escape doors work correctly? Do they 'fail safe' in the open position?				
Do all automatic opening doors on escape routes 'fail safe' in the open position?				
Are fire door seals and self-closing devices in good condition?				
Do all internal self-closing fire doors work correctly?				
Escape lighting				
Do all luminaires and exit signs function correctly when tested?				
Have all emergency generators been tested? (Normally run for one hour.)				
Firefighting equipment				
Is the pressure in 'stored pressure' fire extinguishers correct?				
Additional items from manufacturer's recommendations.				
Three-monthly checks				
General				
Are vehicles blocking fire hydrants or access to them?				
Additional items from manufacturer's recommendations.				
Civ. as a male live also also				
Six-monthly checks General				
Has any firefighting or emergency evacuation lift been tested by				
a competent person?				
Has any sprinkler system been tested by a competent person?	Ш	Ш		
Have the release and closing mechanisms of any fir e-resisting compartment doors and shutters been tested by a competent person?				
Fire warning system				
Has the system been checked by a competent person?				
Escape lighting				
Do all luminaires operate on test for one third of their rated value?				
dditional items from manufacturer's recommendations.				
Annual checks				
Escape routes				
Do all self-closing fire doors fit correctly?				
Is escape route compartmentation in good repair?				
Escape lighting				
o all luminaires operate on test for their full rated duration?				
Has the system been checked by a competent person?				
Firefighting equipment				
Has all firefighting equipment been checked by a competent person?				
Miscellaneous				
Has the smoke and heat ventilation system been tested by a competent person?				
Has external access for the fire service been checked for ongoing availability?				
Are any necessary fire engine direction signs in place?				

Risk Assessment - Record of significant findings Assessment undertaken by Risk assessment for Company Date Completed by **Address** Signature Sheet number Floor/area Use Step 1 – Identify fire hazards Sour ces of ignition Sour ces of fuel Sour ces of oxygen Step 2 – People at risk Step 3 – Evaluate, r emove, r educe and pr otect fr om risk (3.1) Evaluate the risk of the fire occuring (3.2) Evaluate the risk to people from a fire starting in the premises (3.3) Remove and reduce the hazards that may cause a fire (3.4) Remove and reduce the risks to people from a fire Assessment review Completed by Signature Assessment review date Review outcome (where substantial changes have occurred a new record sheet should be used)

Notes

⁽¹⁾ The risk assessment record of significant findings should refer to other plans, records or other documents as necessary.

⁽²⁾ The information in this record should assist you to develop an emergency plan; coordinate measures with other 'responsible persons' in the building; and to inform and train staff and inform other relevant persons.