

OSFM Quarterly Equipment Inspection Checklist/Operations & Maintenance Guidelines For UST System Inspections

Facility Name: Facility ID:

THIS QUARTERLY INSPECTION IS IN ADDITION TO ALL OTHER MONTHLY RELEASE DETECTION AND TESTING REQUIREMENTS

UST Quarterly	/ Inspection Equipment Items (place check mark in last column if unusual conditions (UC)	exist)		
		CHECKED	N/A	UC
Section A.	Tank Leak Detection Records (Circle applicable number)			
1. Automatic Tank Gauge	Monthly passing print out tape			
2. Interstitial Sensors	Monthly status record of normal or equivalent - Annual functional test			
	Last tested: Test due:			
3. S.I.R. (Includes Warren Rogers)	Monthly status report normal or equivalent			
4. Manual Tank Gauging < 600 gal.	Weekly stick measurements with monthly reconciliation			
5. Vapor/Groundwater Monitoring	Monthly log with date, results and inspectors initials			
6. Water in Tank	Monitor ATG for water alarm or check tank utilizing gauge stick and water paste			
Section B.	Tank Component Inspection			
1. Tank Monitoring System	Ensure system has power and is in a normal status with no alarms (daily)			
2. Submersible Sump Covers	Ensure all covers are present, in good condition and seated firmly			
3. Submersible Sump	Ensure no water is in submersible sump that contains interstitial sensors			
	If piping is single wall and corrosion prevention is installed, water is allowed			
4. Electrical	Ensure junction boxes are intact and no obvious wire breaks are visible			
Section C.	Piping Leak Detection Records (Circle applicable number)			
1. Interstitial Sensors	Monthly status record of normal or equivalent - Annual functional test			
	Last tested: Test due:			
2. Mechanical Line Leak Detector	Annual precision test of lines and functionality test of leak detector			
	Last tested: Test due:			
3. Electronic Line Leak Detector	If proof of annual 0.1 gph system leak test is performed, a functionality test of			
	the leak detector is required only - If proof is not available a precision line test			
	will also have to be performed Last tested: Test due:			
Section D.	Piping Component Inspection (Circle applicable number)			
1. Pressurized piping components	Ensure line leak detector is in place, if interstitial sensors are used, ensure they			
	are positioned at the lowest portion of the submersible and dispenser sump			
2. American Suction	Ensure monthly monitoring is in place			
3. Product Piping	Inspect for obvious leaks, deformations, cracks or other abnormalities			
Section E.	Corrosion Protection Records (Circle applicable number)			
Impressed Current System	Monthly log with date, initials of inspector, hour, volt, amp and power on			
	verification - Annual system test: Last tested: Test due:			
2. Sacrificial Anode System	System must be tested every 3 years: Last tested: Test due:			
3. Internal Lining	Must be inspected every 5 years: Last tested: Test due:			
Section F.	Corrosion Component Inspection (Circle applicable number)			
Impressed Current System	Ensure rectifier has power and power light functions, observe and record volt,			
	amp and hour meter readings			
2. Sacrificial Anodes	If anodes and connections are visible in submersible or dispenser sumps,			
	observe for obvious connection breaks of wiring from steel components			
Section G.	Spill Protection			
1. Spill Protection Equipment	Ensure spill containment is in place, clean, dry & no obvious cracks/tears (daily)			
Section H.	Overfill			
1. Automatic Shutoff	Ensure device is in place and free of restrictive items			
2. Overfill Alarm	Ensure device is in place and test function operates properly			
Section I.	Dispensers and Emergency Shut-Offs			
1. Hose and Nozzle Components	Observe for obvious leaks, cracks & deformations. Ensure breakaway is installed	_		
2. Under dispenser	Ensure shear valve is in place and properly anchored. Observe for obvious leaks			
	Ensure interstitial sensors if installed are positioned at the lowest portion			
Castian I	Observe for obvious open electrical junction boxes or broken wiring			
Section J.	Emergency Shut-Off			
1. Emergency Shut-Off	Ensure emergency shut-offs are accessible and have no obvious damage			
Section V	Last tested: Test due:			
Section K.	Emergency Actions			
1. System Alarms	Ensure any alarms have been reported as required by facility operations plan			
2. Spills, Leaks or Release	Ensure any release has been reported as required by facility operations plan			

Remarks n	eeded if un	usual condi	tions exists	(also incud	le the date o	wner was	notified and	actions tak	en):		
Verify tha	t each mon	thly recordi	keeping req		n the 1st pa all that are	_	n accomplis	hed by initia	aling in the	blanks belo	ow. (Initial
		_	Tank	Leak Dete	ction/Inters	titial Monit	toring			_	_
Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
		T .					Leak Detecto		T -	1	T
Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
						_					
1	E - l-	l Manuala	ا ئىرىد		npressed Cu	1	1	Ct	0-+	l N	D
Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
		<u> </u>	<u> </u>	1	1		1			<u> </u>	<u> </u>
dditional	Daily, Mon	thly, Quarte	erly, and An	nual Inspec	ction Items	indicate ho	ow often):				
Daily:											
1onthly:											
uarterly:											
,											
nnually:	Submit annu	al Financial Re	esponsibility R	eport from w	ww.sfm.illinoi	s.gov at Appli	ications & Forn	ns.			
dentify th	a manner ir	n which faci	lity owners	onerators	will properly	v disnosa o	of regulated:	substances	snillad at tl	ne facility:	
uentily til	e manner n	i willcii iaci	iity Owners/	operators	wiii properi	y uispose o	i regulateu	substances	spilled at ti	ie raciiity.	
A/B Opero	itors must	conduct th	he quarterl	y inspection	ons person	ally. Sign 8	& date the j	form when	inspection	n is done.	
fusina th	is form as	nart of you	ur Operatio	nc & Mair	ntananca D	lan attac	h the list of	vour class	1 /R 2. C C	nerators !	2. vour
_	-		-				t sign the O	-		-	-
-		-		-	e jucinty O		_	QIVI FIUII V	vitii tile Aj	ъ Орегиц	n, but
my uie A	, ο ομειαί	or is requi	ieu to siyii	ane Quuit	city mspec	aon reput					
									_		
rinted Na	ne of A/B C	perator		•	Signature o	of A/B Oper	ator		-	Date of I	nspection